



Project: Passive Fire Protection System -
Blast Performance Testing.

Certificate Number: BHM 9998010/3

Client: Salamis (Marine & Industrial) Ltd.
Greenhole Place,
Bridge of Don,
Aberdeen AB23 8EU.

Office: Birmingham.

Client's Order Number: 0027128/4029.

Date: 31.01.00.

Order Status: Incomplete.

Inspection Dates

First: 12.02.99

Final: 31.01.00.

This certificate is issued to Salamis (Marine & Industrial) Limited to certify that at their request the undersigned Surveyor to Lloyd's Register did attend at the premises of the Building Research Establishment Limited, Cardington Laboratory Test Facility for the purpose of witnessing blast tests on the undernoted equipment:-

DESCRIPTION.


Test Report No.

**Procon Flexible Jet Fire Jacket System-
Drawing No: 4029/007.
Test Sample 3.**

TCR 46/99.

The following scope of inspection was carried out against purchase order requirements:-

1. Inspect the test sample mounted horizontally in the explosion chamber prior to testing.
2. Witness three blast tests at 78.0, 126.0 and 140.0 kPa (averaged Pmax) with visual inspection of the test sample after each test.
3. Test report TCR 46/99 dated 12.12.99 reviewed and considered to be a true reflection of the tests carried out.


D.G. Lown
Surveyor to Lloyd's Register.